

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Whitewater Lift Station Control Panel Emergency Repair

Work Session/Regular Session

DATE OF MEETING: June 22, 2021

BUDGET IMPACT: \$53,140.00

FUNDING SOURCE:

- Annual
- Capital
- GEFA
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Whitewater Lift Station Control Panel Emergency Repair

HISTORY, FACTS AND ISSUES: The Whitewater lift station is a triplex station on our main trunk line going to the LAS. The control panel and related components have deteriorated beyond repair due to the sewer gases coming from the station. Staff has deemed this to be an emergency repair to prevent a catastrophic failure. The control panel is located directly beside the wet well in close proximity to the sewer gases. Staff has received three quotes to rebuild and relocate the control panel and associated components. Cowart Electric submitted the low quote for \$53,140.00. Staff recommends approval for Cowart Electric to make the necessary repairs to the Whitewater lift station control panel for \$53,140.00.

OPTIONS: 1. Approve emergency repairs to the Whitewater lift station control panel.
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: