

**Lowndes County Historic Courthouse  
GMP Construction Documents Review Notes & Clarifications  
April 22, 2022**

Patching

1. Regarding restoration work:
  - If you look for it, then you will see it.
  - There is always more that could be done.
2. Differences between patched and existing materials will be “apparent” (1.3, E/013591).

Insurance

3. If incurred, builder’s risk insurance deductibles, are not included.
4. Builder’s risk insurance coverage is by Lowndes County.

**Demolition**

5. Engineering survey of existing building is not included (3.1, C/024119).

**Masonry**

6. Existing memorials and monuments remain as-is (A-0.10).

**Glass**

7. Testing of three windows is included instead of testing of “...three windows of each type...” (3.3, B, 4/085200).

**Radio Communications System**

8. In-building emergency radio communication enhancement system is not shown or included (NFPA 1, section 11.10).