



Cross-Connection Control Plan

Lowndes County Utilities

- Fire Protection Systems that utilize no chemicals
- Commercial Facility that comes into contact with no dangerous chemicals
- Water Fountain or Cooler that provides drinking water for human consumption
- Chiller Tank with no chemicals added
- Animal watering
- Ice Cream Dipper Well
- Building Center or Lumber Yard
- Fire Station
- Funeral Home where no preparation takes place
- Convenience Store or Gas Station
- Camp Ground with no vehicle hook-up
- Grocery Store with no meat processing
- Hotel or Motel (less swimming pool)
- Drugstore or Pharmacy with no on-site compounding
- Recreation Center (less swimming pool)
- Arena or Fitness Center
- Kennel or Animal Grooming Facility
- Jail/ Penitentiary with normal water use
- Opticians Office
- Police Office or Facility
- Library or Resource Center
- Museum
- Office Building -- general use
- Shopping Center or Retail
- Theater
- Multiple Unit Residential Locations

Facilities that are considered "High hazard" will be required to install a Reduced Pressure principal backflow preventer (RP or RPDA) in a location that is not subject to possible flooding. Building operations and water uses that are generally considered high hazard are:

B. High Hazard

- Aircraft Facilities
- Amusement Parks
- Automotive Plants
- Locations with Auxiliary Water
- Beverage Bottling Facilities
- Large Boilers or Hot Water Systems
- Breweries
- Canneries
- Medical Buildings
- Metal Plating Plants
- Metal Processing, Manufacturing, Cleaning or Fabricating Plants
- Missile Plants
- Morgues or Autopsy Facilities
- Motion Picture Studios
- Nursing Homes with food prep