



D. Backflow prevention devices will be tested more frequently than specified in A. above, in cases where there is a history of test failures, and the Department feels that due to the degree of hazard involved, additional testing is warranted. Cost of the additional tests will be borne by the owner.

XI. Records and Reports

A. Records

The Department will initiate and maintain the following for a minimum of three years:

1. Most current hazard assessment conducted pursuant to Section 608 of the Georgia State Minimum Standard Plumbing Code (IPC);
2. Locations and types of backflow protections and associated hazards;
3. Results of all backflow testing and air gap inspections;
4. Repairs made to, or replacement or relocation of, backflow protection;
5. Summaries of the information in items 1 through 4 above;

XII. Fees and Charges

The Department will publish a list of fees or charges for the following services or permits:

1. Testing fees; \$150.00
2. Re-testing fees; \$200.00
3. Fee for re-inspection; \$200.00
4. Charges for after-hours inspections or tests; \$350.00