## LOWNDES COUNTY BOARD OF COMMISSIONERS COMMISSION AGENDA ITEM

## SUBJECT: Spring Creek Well Pilot Study

DATE OF MEETING: February 27, 2024

Work Session/Regular Session

BUDGET IMPACT: \$71,500.00 FUNDING SOURCE:

- (X) Annual
- () Capital
- () N/A
- () SPLOST
- () TSPLOST

## COUNTY ACTION REQUESTED ON:

HISTORY, FACTS AND ISSUES: The Spring Creek Well has high organic levels in the water being pumped from the aquifer that creates disinfection by-products when the water is chlorinated. This is causing elevated trihalomethanes and haloacidic acids in our potable water. Staff and Lovell Engineering Associates (LEA) put out an RFP for a pilot study to determine the feasibility of installing a water treatment plant to remove the organics for the well water. Harn R/O Systems, Inc. meets all requirements of the RFP. The costs for a three-month pilot is \$62,650.00, and an extra month can be added if needed, for an additional \$8,850.00. Staff recommends approval and authorize the Chairman to sign the agreement with Harn R/O Systems, Inc. with a not to exceed price of \$71,500.00.

**OPTIONS: 1. Approve** 

2. Board's Pleasure

**RECOMMENDED ACTION: Approve** 

**DEPARTMENT**: Utilities

**DEPARTMENT HEAD:** Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: