

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Blue Lake Lift Station Pump Repair

DATE OF MEETING: July 22, 2025

Work
Session/Regular
Session

BUDGET IMPACT: \$44,661.00

FUNDING SOURCE:

- ☒ Annual
- ☐ Capital
- ☐ N/A
- ☐ SPLOST
- ☐ TSPLOST

COUNTY ACTION REQUESTED ON: Approve Blue Lake Lift Station Pump Repair

HISTORY, FACTS AND ISSUES: The Blue Lake lift station is a duplex lift station on our main trunk line. This station is currently running on one pump. The pump that is out of service is a 60-horsepower Flygt pump. We have a quote from Xylem, Inc. to repair this pump for \$44,661.00. Additionally, we have a quote for a new replacement pump from Xylem, Inc. for \$62,714.00. Staff recommends the pump be repaired for \$44,661.00.

OPTIONS: 1. Approve
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: