

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Peterson Road Lift Station Pump Repair

Work
Session/Regular
Session

DATE OF MEETING: January 27, 2026

BUDGET IMPACT: \$24,400.00

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Peterson Road Lift Station Pump Repair

HISTORY, FACTS AND ISSUES: Pump one at the Peterson Road lift station began running high amps. After troubleshooting, the pump was sent to Xylem for further diagnostics. After examining the pump, Xylem determined the cost of repairs would be \$24,400.00. The cost of a new pump is \$76,440.25. Staff recommends approval for the pump to be repaired for \$24,400.00.

OPTIONS: 1. Approve
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: