parking spaces through sharing adjacent parking for two or more proximate uses because peak demand periods for proposed land uses do not occur at the same time periods.

Staff Review Comments:

Engineering & Stormwater Department: Vehicular use areas are required to be asphalt or concrete pavement.

Fire Department: The fire department will need access to at least three sides to the structure.

Landscape: Must meet all requirements for new development in the LDR Chapter 328. Street yard(s), interior vehicular use area, side/rear yard(s), buffering, and any required tree removals/replacements.

Plan Review: No comments Public Works: No comments

Historic Preservation: No comments **Police:** No comments

Utilities: No comments

Attachments:

Zoning Location Map Aerial Map Site Plan